
KANSAI Automation Co.,Ltd.

News Letter vol.9

Date of issue: March / 2017



Difficult Conditions for Non-contact Measurement





Irregular ultrasonic reflection can occur in dusty environments and reliable indication can't be obtained.

Low dielectric constant


If the dielectric constant is low, reliable reflected waves can't be obtained.

Radar

By applying Capacitance Level Meter,

The actual surface can be correctly detected since the electrode touches the material all the time. We craft any shaped electrode with high reliability based on the customer's application.

Variations of Electrodes



Above are our standard electrodes. We craft any electrode suitable to your application.

For any inquiry, feel free to contact our sales!